

**Amendment No. 10 Board Bill Number 49 Sponsored by Alderwoman Anne Schweitzer
Introduced by Alderwoman Anne Schweitzer**

To amend said Board Bill, Page 14, Line 5 as follows:

Beginning on Page 14, Line 5 after the word(s), “On-site”; insert the following words and figures, “stand alone”.

Plain Language: Amends this provision to clarify this does not directly require generators with internal fuel storage to be subject to be screened.

**Amendment No. 11 to Board Bill Number 49 Sponsored by Alderwoman Anne Schweitzer
Introduced by Alderwoman Anne Schweitzer**

To amend said Board Bill, Page 13, Line 21 as follows:

Beginning on Page 13, Line 21 after the word(s), “primary frontages”; insert the following words and figures:

“1. For the purposes of this provision enclosed shall include sound attenuated or soundproof enclosures that are standard for the original equipment manufacturer.”

Plain Language: Provides clarification the a manufacturer standard enclosure will satisfy the enclosure and screening requirements of 26.77.050 d.iii